

TECHNICAL EXHIBIT 15

PM SCHEDULE						
SEWAGE AND WASTE WATER SYSTEMS						
Frequency	D	W	M	Q	S	A
Check manholes.		X				
Check lift stations. Operate manually.	X					
Visually inspect dry and wet wells.		X				
Lubricate pumps, shafts and bearings.			X			
Lubricate motors.			X			
Inspect physical condition of all plant equipment and facilities.	X					
Maintain all equipment, as required IAW TM 5-661.						
Check grit cambers for operation.					X	
Inspect oil separators for operation and remaining capacity			X			
Perform lagoon sampling IAW permit. Frequency of sampling shall be IAW permit.		X				
Complete all required NC state and Federal wastewater reports, as required.						X
Perform Ground Water monitoring (Form GW-59), three times per year						
Perform visual inspection of storm water system outfall.				X		
Perform analytical monitoring of outfall					X	
Flush sanitary sewer manholes and main lines. Do one third (1/3) of total system each year.						
Complete all inspections and sampling to comply with MOTSU's Storm Water discharge permit (NCS000208). Required on a bi-weekly basis.						
Obtain and maintain data to meet EPA NPDES permit requirements and North Carolina pollution standards for receiving waters.			X			X

TECHNICAL EXHIBIT 15

PM SCHEDULE						
SEWAGE AND WASTE WATER SYSTEMS						
Frequency	D	W	M	Q	S	A
GENERAL						
Complete Preventive Maintenance Record upon completion and maintain on file.	X					
Report all uncorrected deficiencies to Contracting Officer's Representative.		X				